



New Mexico Regulation and Licensing Department

CONSTRUCTION INDUSTRIES DIVISION

P.O. Box 25101 ▪ Santa Fe, NM 87504 ▪ Ph. (505) 476-4675 ▪ Fax (505) 476-4685
 5500 San Antonio Dr. NE ▪ Albuquerque, NM 87109 ▪ Ph. (505) 222-9800 ▪ Fax (505) 765-5670
 505 S. Main St., Suite 103 ▪ Las Cruces, NM 88004 ▪ Ph (575) 524-6320 ▪ Fax (575) 524-6319
www.rld.state.nm.us/construction

STATE OF NEW MEXICO THERMAL BYPASS INSPECTION CHECKLIST

Home Address: _____ City: _____ State: NM

Thermal Bypass	Inspection Guidelines	Corrections Needed	Builder Verified	Rater Verified	N/A
1. Overall Air Barrier and Thermal Barrier Alignment	Requirements: Insulation shall be installed in full contact with sealed interior and exterior air barrier except for alternate to interior air barrier under item no. 2 (<i>Walls Adjoining Exterior Walls or Unconditioned Spaces</i>)				
	All Climate Zones:				
	1.1 Overall Alignment Throughout Home	Y / N	Y / N	Y / N	Y / N
	1.2 Garage Band Joist Air Barrier (at bays adjoining conditioned space)	Y / N	Y / N	Y / N	Y / N
	1.3 Attic Eave Baffles Where Vents/Leakage Exist	Y / N	Y / N	Y / N	Y / N
2. Walls Adjoining Exterior Walls or Unconditioned Spaces	Requirements: Fully insulated wall aligned with air barrier at both interior and exterior, OR Alternate for Climate Zones 1 thru 3, sealed exterior air barrier aligned with RESNET Grade 1 insulation fully supported Continuous top and bottom plates or sealed blocking				
	2.1 Wall Behind Shower/Tub	Y / N	Y / N	Y / N	Y / N
	2.2 Wall Behind Fireplace	Y / N	Y / N	Y / N	Y / N
	2.3 Insulated Attic Slopes/Walls	Y / N	Y / N	Y / N	Y / N
	2.4 Attic Knee Walls	Y / N	Y / N	Y / N	Y / N
3. Floors between Conditioned and Exterior Spaces	Requirements: Air barrier is installed at any exposed fibrous insulation edges Insulation is installed to maintain permanent contact with sub-floor above including necessary supports (e.g., staves for blankets, netting for blown-in) Blanket insulation is verified to have no gaps, voids or compression. Blown-in insulation is verified to have proper density with firm packing				
	3.1 Insulated Floor Above Garage	Y / N	Y / N	Y / N	Y / N
	3.2 Cantilevered Floor	Y / N	Y / N	Y / N	Y / N
	4.1 Duct Shaft	Y / N	Y / N	Y / N	Y / N
	4.2 Piping Shaft/Penetrations	Y / N	Y / N	Y / N	Y / N
5. Attic / Ceiling Interface	Requirements: All attic penetrations and dropped ceilings include a full interior air barrier aligned with insulation with any gaps fully sealed with caulk, foam or tape Movable insulation fits snugly in opening and air barrier is fully gasketed				
	5.1 Attic Access Panel (fully gasketed and insulated)	Y / N	Y / N	Y / N	Y / N
	5.2 Attic Drop-down Stair (fully gasketed and insulated)	Y / N	Y / N	Y / N	Y / N
	5.3 Dropped Ceiling/Soffit (full air barrier aligned with insulation)	Y / N	Y / N	Y / N	Y / N
	5.4 Recessed Lighting Fixtures (ICAT labeled and sealed to drywall)	Y / N	Y / N	Y / N	Y / N
6. Common Walls Between Dwelling Units	Requirements: Gap between drywall shaft wall (i.e., common wall) and the structural framing between units is fully sealed at all exterior boundary conditions				
	6.1 Common Wall Between Dwelling Units	Y / N	Y / N	Y / N	Y / N

Inspected by: (Check one) Energy Rater **OR** Builder **OR** Code Official Inspection Date: ____/____/____

Company/Government Entity Name: _____

Signature: _____ Printed Name _____